

VILLAGE OF SWANTON
NPDES PERMIT # 2PB00025*LD

2018 CSO ANNUAL NOTICE

LOCATION -RECEIVING WATER		2018												TOTAL
		Jan	Feb	Mar	Apr	May	Jun	July	Aug	Sep	Oct	Nov	Dec	
002	Storm Basin Discharge	0	0	0	0	0	0	0	0	0	0	0	0	0
300	Sanitary Sewer Overflow	0	0	0	0	0	0	0	0	0	0	0	0	0
008	Main St. Bridge (NW)-AI Creek	0	0	0	0	0	0	0	0	0	0	0	0	0
013	Dodge St. RR Bridge-AI Creek	0	0	0	0	1	0	0	0	0	0	0	0	1
016	High School Foot Bridge - AI Creek	0	0	0	0	1	0	0	0	0	0	0	0	1
018	Fulton St. - AI Creek	0	0	0	0	0	0	0	0	0	0	0	0	0
019	Main St. (Apple Orchard) - AI Creek	0	0	0	0	0	0	0	0	0	0	0	0	0
020	E. Garfield (Street Dept.) - AI Creek	0	0	0	0	2	1	0	1	0	0	0	0	4
024	Brookside @ Crestwood-Mary Wander Ditch	0	0	1	1	1	1	0	3	1	1	1	1	11
027	Church St. - Mary Wander Ditch	0	0	0	0	0	0	0	0	0	0	0	0	0
028	Hallett @ Zeiter Way - Mary Wander Ditch	0	0	1	1	3	1	0	5	1	1	1	1	15
TOTAL CSO DISCHARGES		0	0	2	2	8	3	0	9	2	2	2	2	32
Rainfall (inches)		1.13	3.90	3.79	3.67	6.97	4.61	1.33	5.74	2.50	2.00	4.55	3.06	43.25
Snowfall (inches)		6.6	10.3	1.9	1.5	0	0	0	0	0	0	1.7	0.03	22.03

No active dry weather overflows observed.

Sewer separation projects completed

- Project 4 Broadway (Zeiter Way) January 2007
- Project 2 Fulton Street September 2011
- Project 2 Lincoln Woodland September 2012
- Project 6 Clark Street June 2016
- Project 7 Church Harrison Lawrence October 2018

Upcoming sewer separation projects

- Project 10 Hallett Parkside Woodside Brookside starting Summer 2019