

VILLAGE OF SWANTON
NPDES PERMIT # 2PB00025*LD

2019 CSO ANNUAL NOTICE

LOCATION -RECEIVING WATER		2019												TOTAL
		Jan	Feb	Mar	Apr	May	Jun	July	Aug	Sep	Oct	Nov	Dec	
002	Storm Basin Discharge													0
300	Sanitary Sewer Overflow													0
008	Main St. Bridge (NW)-AI Creek													0
013	Dodge St. RR Bridge-AI Creek													0
016	High School Foot Bridge - AI Creek						1							1
018	Fulton St. - AI Creek								1					1
019	N Main St. - AI Creek				1	2								3
020	E. Garfield (Street Dept.) - AI Creek													0
024	Brookside @ Crestwood-Mary Wander Ditch	1	1	1	3	4	2	4	4	1			1	22
027	Church St. - Mary Wander Ditch								1					1
028	Hallett @ Zeiter Way - Mary Wander Ditch		2			4	4	5	5	4	3	1	1	29
TOTAL CSO DISCHARGES		1	3	1	4	10	7	9	11	5	3	1	2	57
Rainfall (inches)		1.18	2.57	3.05	6.33	6.05	4.62	6.04	5.70	3.13	4.43	0.98	2.31	46.39
Snowfall (inches)		11.22	2.87	1.79	0	0	0	0	0	0	0	4.01	2.57	22.46

No active dry weather overflows observed.

Sewer separation projects completed

- Project 4 Broadway (Zeiter Way) January 2007
- Project 2 Fulton Street September 2011
- Project 2 Lincoln Woodland September 2012
- Project 6 Clark Street June 2016
- Project 7 Church Harrison Lawrence October 2018

Upcoming sewer separation projects

- Project 10 Hallett Parkside Woodside Brookside begins March 2020