

**VILLAGE OF SWANTON**  
**NPDES PERMIT # 2PB00025\*LD**  
**2020 CSO ANNUAL NOTICE**

LOCATION -RECEIVING WATER		2020												TOTAL
		Jan	Feb	Mar	Apr	May	Jun	July	Aug	Sep	Oct	Nov	Dec	
002	Storm Basin Discharge													0
300	Sanitary Sewer Overflow													0
008	Main St. Bridge (NW)-AI Creek								1					1
013	Dodge St. RR Bridge-AI Creek													0
016	High School Foot Bridge - AI Creek								1	1				2
018	Fulton St. - AI Creek								1	1				2
019	N Main St. - AI Creek	1												1
020	E. Garfield (Street Dept.) - AI Creek							1	1					2
024	Brookside @ Crestwood-Mary Wander Ditch	1		1										2
027	Church St. - Mary Wander Ditch													0
028	Hallett @ Zeiter Way - Mary Wander Ditch			1	1	1	2	1	1	2	2	3	1	15
<b>TOTAL CSO DISCHARGES</b>		<b>2</b>	<b>0</b>	<b>2</b>	<b>1</b>	<b>1</b>	<b>2</b>	<b>2</b>	<b>5</b>	<b>4</b>	<b>2</b>	<b>3</b>	<b>1</b>	<b>25</b>
<b>Rainfall (inches)</b>		3.56	0.77	3.58	1.92	4.36	2.02	3.40	3.01	2.20	2.54	2.60	1.23	<b>31.18</b>
<b>Snowfall (inches)</b>		0	10.6	0	0.04	0	0	0	0	0	0	1.86	4.5	<b>17</b>

No active dry weather overflows observed.

Duration of wet weather CSO discharges: not active during inspections

Cause of wet weather CSO discharges: due to rainfall

Dry weather CSO discharges: None observed during inspections

Public access areas impacted by CSO discharges: AI Creek

**Sewer separation projects completed**

Project 4 Broadway (Zeiter Way) January 2007

Project 2 Fulton Street September 2011

Project 2 Lincoln Woodland September 2012

Project 6 Clark Street June 2016

Project 7 Church Harrison Lawrence October 2018

Project 10 Hallett Parkside Woodside Brookside August 1, 2020

**Upcoming sewer separation projects**

Project 8 & 9 to begin September 7, 2021 and operational by September 7, 2022

Project 3 & 11 tentatively begins in late 2023 or early 2024