

VILLAGE OF SWANTON
NPDES PERMIT # 2PB00025*LD
2021 CSO ANNUAL NOTICE

LOCATION -RECEIVING WATER		2021												TOTAL
		Jan	Feb	Mar	Apr	May	Jun	July	Aug	Sep	Oct	Nov	Dec	
002	Storm Basin Discharge													0
300	Sanitary Sewer Overflow													0
008	Main St. Bridge (NW)-AI Creek													0
013	Dodge St. RR Bridge-AI Creek						1							1
016	High School Foot Bridge - AI Creek			1		1	1	2			1			6
018	Fulton St. - AI Creek		1	1	1					1	3			7
019	N Main St. - AI Creek			2	1			3		1	3			10
020	E. Garfield (Street Dept.) - AI Creek							1						1
024	Brookside @ Crestwood-Mary Wander Ditch					1	3	3			3			10
027	Church St. - Mary Wander Ditch								1					1
028	Hallett @ Zeiter Way - Mary Wander Ditch	2		1			2	2	1	1	4		1	14
TOTAL CSO DISCHARGES		2	1	5	2	2	7	11	2	3	14	0	1	50
Rainfall (inches)		1.03	0.50	1.35	1.08	1.04	6.10	2.35	1.10	4.01	3.93	0.00	0.89	23.38
Snowfall (inches)														0

No active dry weather overflows observed.

Duration of wet weather CSO discharges: not active during inspection

Cause of wet weather CSO discharges: due to rainfall

Dry weather CSO discharges: None observed during inspection

Public access areas impacted by CSO discharges: AI Creek

Sewer separation projects completed

Project 4 Broadway (Zeiter Way) January 2007

Project 2 Fulton Street September 2011

Project 2 Lincoln Woodland September 2012

Project 6 Clark Street June 2016

Project 7 Church Harrison Lawrence October 2018

Project 10 Hallett Parkside Woodside Brookside August 1, 2020

Upcoming sewer separation projects

Project 8 & 9 to begin September 7, 2021 and operational by September 7, 2022

Project 3 & 11 tentatively begins in late 2023 or early 2024