

VILLAGE OF SWANTON
NPDES PERMIT # 2PB00025*LD
2022 CSO ANNUAL NOTICE

LOCATION -RECEIVING WATER		2022												
		Jan	Feb	Mar	Apr	May	Jun	July	Aug	Sep	Oct	Nov	Dec	TOTAL
002	Storm Basin Discharge													0
300	Sanitary Sewer Overflow													0
008	Main St. Bridge (NW)-AI Creek													0
013	Dodge St. RR Bridge-AI Creek													0
016	High School Foot Bridge - AI Creek									1				1
018	Fulton St. - AI Creek									1				1
019	N Main St. - AI Creek													0
020	E. Garfield (Street Dept.) - AI Creek													0
024	Brookside @ Crestwood-Mary Wander Ditch													0
027	Church St. - Mary Wander Ditch													0
028	Hallett @ Zeiter Way - Mary Wander Ditch			1		2	3	3	1	2				12
TOTAL CSO DISCHARGES		0	0	1	0	2	3	3	1	4	0	0	0	14
Rainfall (inches)		0.64	3.15	2.70	1.79	3.82	2.99	4.51	4.15	2.75	0.91	2.12	1.89	31.42
Snowfall (inches)														0

No active dry weather overflows observed.

Duration of wet weather CSO discharges: not active during inspection

Cause of wet weather CSO discharges: due to rainfall

Dry weather CSO discharges: None observed during inspection

Public access areas impacted by CSO discharges: AI Creek

Sewer separation projects completed

Project 4 Broadway (Zeiter Way) January 2007

Project 2 Fulton Street September 2011

Project 2 Lincoln Woodland September 2012

Project 6 Clark Street June 2016

Project 7 Church Harrison Lawrence October 2018

Project 10 Hallett Parkside Woodside Brookside August 2020

Project 8 & 9 September 2022

Upcoming sewer separation projects

Project 3 & 11 & 12 tentatively begins in late 2023 or early 2024