

VILLAGE OF SWANTON

NPDES PERMIT #2PB00025\*LD

2023 ANNUAL NOTICE- SUMMARY OF COMBINED SEWER OVERFLOW DISCHARGES

		CSO Location (Discharge in gallons)										
		002	300	008	013	016	018	019	020	024	027	028
Date of Discharge	Rainfall on event (inches)	Storm Basin Discharge	System Wide Sanitary Sewer Overflow	Main St. Bridge (NW)-AI Creek	Dodge St. RR Bridge-AI Creek	High School Foot Bridge-AI Creek	Fulton St.-AI Creek	N. Main St.-AI Creek	E. Garfield (Street Dept. )-AI Creek	Brookside @ Crestwood-Mary Wander Ditch	Church St.-Mary Wander Ditch	Hallett @ Zeiter Way-Mary Wander Ditch
2/23/2023	2.00											20000
2/28/2023	1.40											14000
3/6/2023	1.36											13600
4/4/2023	0.92											9200
4/6/2023	0.11											1100
6/26/2023	0.99											9900
7/27/2023	2.23											22300
7/31/2023	1.00											10000
8/7/2023	0.46					4600						
8/24/2023	2.10							21000				21000
8/25/2023	0.57											5700
9/7/2023	0.51											5100
9/29/2023	0.28											2800

Total	13.93	0	0	0	0	4600	0	21000	0	0	0	134700
Average	1.07	0	0	0	0	4600	0	21000	0	0	0	11225
Total CSO Discharge for Year in Gallons:				160300								